

Annual Drinking Water Quality Report

PWS Number. TX2200028

TOWN OF LAKESIDE

Consumer Confidence Report (CCR)

Annual Water Quality Report for the period of January 1 to December 31, 2012.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

This information is available at Lakeside Town Hall, 9830 Confederate Park Road Lakeside, Texas. Monday through Friday 7:30 am to 4:30 pm and is also available online at the Town of Lakeside's webpage at lakesidetexas.us.

INFORMATION ABOUT SECONDARY CONTAMINANTS

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (817)237-1234.

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not cause for health concerns. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

Immuno-compromised persons such as persons undergoing chemotherapy, organ transplant recipients, persons with HIV/AIDS, or other immune system disorder, some elderly and infants can be particularly at risk from infections.

Special Notice

Required Language for ALL Community Public Water Systems

These people should seek advice about drinking water from their health care providers. EPA/CIC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

PUBLIC PARTICIPATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Location: TOWN OF LAKESIDE
CITY COUNCIL MEETING
TOWN HALL MEETING ROOM
9830 Confederate Park Road
Lakeside, TX 76108

Time: Wednesday July 10, 2013 at 6:30 pm

For more information regarding this report contact: Craig Bennett
Water Superintendent 817 237-1234

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (817)237-1234.

Sources of Drinking Water

TOWN OF LAKESIDE: Ground Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detection of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Craig Bennett 817 237-1234.

Other Sources of Water

The Town of Lakeside has an Interconnection Emergency Water agreement with the City of Azle. The Source of Azle's water is Eagle Mountain Lake. Lakeside used the interconnection for 4 months in 2012. The interconnection was only used to supplement the Town's water supply during periods of high water demand or when necessary when one of the town's wells was down. Who to contact for water quality information on City of Azle water is Ron Burton the Azle Water Plant Superintendent 817 444-3751.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
1 - 9216 WATERCRESS DR	9216 WATERCRESS DR	GW	<u>A</u>	<u>Paluxy</u>
11 - 150' W OF 5	150 FT W OF WELL 5	GW	<u>A</u>	<u>Paluxy</u>
12T - BETWEEN WELLS 6, 7	BETWEEN WELLS 6 & 7	GW	<u>A</u>	<u>Trinity</u>
13 - 9216 WATERCRESS DR	9216 WATERCRESS DR	GW	<u>A</u>	<u>Trinity</u>
14 - 9216 WATERCRESS DR	9216 WATERCRESS DR	GW	<u>A</u>	<u>Trinity</u>
15T - 304 AQUILA ST	304 AQUILA ST	GW	<u>A</u>	<u>Paluxy</u>
16 - MARY JANE LN	MARY JANE LN	GW	<u>A</u>	<u>Trinity</u>
2 - 9216 WATERCRESS DR	9216 WATERCRESS DR	GW	<u>A</u>	<u>Twin Mountain</u>
3 - 9216 WATERCRESS DR	9216 WATERCRESS DR	GW	<u>A</u>	<u>Paluxy</u>
4 - 9224 WATERCRESS DR	9224 WATERCRESS DR	GW	<u>A</u>	<u>Paluxy</u>
5 - 9224 WATERCRESS DR	9224 WATERCRESS DR	GW	<u>A</u>	<u>Paluxy</u>
6 - 9820 CONFEDERATE PARK	9820 CONFEDERATE PARK	GW	<u>A</u>	<u>Paluxy</u>
7 - 9824 CONFEDERATE PARK	9824 CONFEDERATE PARK	GW	<u>A</u>	<u>Paluxy</u>
8 - 9830 CONFEDERATE PARK	9830 CONFEDERATE PARK	GW	<u>A</u>	<u>Paluxy</u>
9 - 304 AGUILLA ST	304 AGUILLA ST	GW	<u>A</u>	<u>Paluxy</u>

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	08/31/2011	1.3	1.3	0.198	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	08/31/2011	0	15	5.69	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

Water Quality Test Results

ppb:

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm:

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppt

parts per trillion, or nanograms per liter (ng/L)

ppq

parts per quadrillion, or picograms per liter (pg/L)

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAAs)*	05/19/2010	3.2	2.5 - 3.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	05/19/2010	36.4	17.2 - 36.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Antimony	02/18/2009	0.037	0.035 - 0.037	6	6	ppb	N	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic	02/18/2009	0.501	0.434 - 0.501	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	02/18/2009	0.124	0.0279 - 0.124	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	02/18/2009	1.58	0.652 - 1.58	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2012	1.34	0.62 - 1.34	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2012	1	0.21 - 1.14	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	02/18/2009	1.63	0 - 1.63	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Thallium	02/18/2009	0.156	0 - 0.156	0.5	2	ppb	N	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination

Beta/photon emitters	2012	5.8	5.8 - 5.8	0	50	pCi/L *	N	Decay of natural and man-made deposits.
----------------------	------	-----	-----------	---	----	---------	---	---

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Combined Radium 226/228	2012	2	2 - 2	0	5	pCi/L	N	Erosion of natural deposits.
Gross Alpha Compliance	2012	6.5	6.5 - 6.5	0	15	pCi/L	N	Erosion of natural deposits.